



**NOTES**

1. FOR SYMBOL LIST AND GENERAL NOTE'S SEE DWG. ED-01.
2. PROVIDE MODIFICATIONS TO THE WIRING TERMINATIONS IN THE EXISTING MOTOR CONTROL CENTER TO INCORPORATE EMERGENCY POWER ALTERNATE AS SHOWN.
3. PROVIDE TRANSFER SWITCHES AND DISCONNECT SWITCHES BY EXISTING MOTOR CONTROL CENTER AND CONNECT AS INDICATED.
4. ACTIVATE SPARE 600 AMP. BREAKER MODULE OR REPLACE TRIPPING TO 500 AMP. TO PROVIDE EMERGENCY POWER TO THE EXISTING AUXILIARY CHILLED WATER PUMP SYSTEM WITH 6-250A/3W & 1 GRD IN 4" CONDUIT.



ORIGINAL SIGNED & SEALED BY  
H.Y. P.E. (OR R.A.)

**Joseph R. Loring  
& Associates, Inc.**  
consulting engineers

One Pennsylvania Plaza  
New York, New York 10119-0045  
Tel (212) 563-7400, Fax (212) 563-7300

THE OFFICE OF  
DAVID  
ELLIOT  
LEIBOWITZ  
PC

ARCHITECTS + PLANNERS  
70 WEST 40TH STREET NEW YORK, NY 10018

72. FIL/AL/04 Nov. 2019/004

LESLIE E ROBERTSON

**ASSOCIATES, R.L.P.**  
**CONSTRUCTION SERVICES**

211 EAST 40TH STREET  
NEW YORK, NY 10018-5002

WE HEREBY CERTIFY THAT THIS IS A TRUE AND CORRECT COPY OF ONE OF THE CONTRACT DRAWINGS CONSTITUTING A PART OF CONTRACT NO. *WTC-945,011* IN THE FORM IN WHICH SAID DRAWINGS EXISTED AT THE TIME THE SAID CONTRACT WAS EXECUTED BY THE PARTIES.

DATE 1/16/98 Ernest A. Hickman

1-100 P.K. [Signature]

A	12/12/97	MONEY EQUIP. AMRGCT		
	11/17/97	ISSUED FOR BID		

NO.	DATE	REVISION	APPROVED
Engineering Department			
Design Divisions			

The				
World				
Trade				
Center				

Title  
**STANDBY POWER  
5 WORLD TRADE CENTER**

ELECTRICAL

**B3 LEVEL  
CONDENSER WATER  
SYSTEM MODIFICATION**

This drawing subject to conditions in contract.  
All inventions, ideas, designs and methods  
herein are reserved to Port Authority and  
may not be used without it's written consent.

<u>F.F.P.</u>	<u>MAR.</u>	<u>.</u>
Designed by	Drawn by	Check by

Date	Scale
11/17/97	AS NOTED

Contract Number	Drawing Number
WTC-845.071	E1-08

